

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
21 Market St.
Paterson, NJ 07504

Sample Date: 9-6-18

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE/TIME	ACTION LEVEL UG/L
18-6547.FB	Field Blank	06:32	LEAD/1030	200.9	<2	9-10-18/13:38	15
18-6547.1	3 rd Floor Fountain	06:32	LEAD/1030	200.9	<2	9-10-18/13:50	15
18-6547.2	Kitchen Sink	06:37	LEAD/1030	200.9	<2	9-10-18/13:54	15
18-6547.3	2 nd Floor Fountain	06:40	LEAD/1030	200.9	<2	9-10-18/13:58	15
18-6547.4	Nurses Sink	06:44	LEAD/1030	200.9	<2	9-10-18/14:02	15

UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion). < = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 9-13-18

College Achieve Charter School-Paterson
9/6/18 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	18-6547.FB	JRH Labs	15083	9/6/2018	06:32	200.9	9/10/2018	13:38	<2.00	2.00	1	N	
3rd Floor Fountain	N	18-6547.1	JRH Labs	15083	9/6/2018	06:32	200.9	9/10/2018	13:50	<2.00	2.00	1	N	
Kitchen Sink	N	18-6547.2	JRH Labs	15083	9/6/2018	06:37	200.9	9/10/2018	13:54	<2.00	2.00	1	N	
2nd Floor Fountain	N	18-6547.3	JRH Labs	15083	9/6/2018	06:40	200.9	9/10/2018	13:58	<2.00	2.00	1	N	
Nurses Sink	N	18-6547.4	JRH Labs	15083	9/6/2018	06:44	200.9	9/10/2018	14:02	<2.00	2.00	1	N	