

College Achieve Paterson Charter School

21 Market St.
Paterson, NJ 07501

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
21 Market St.
Paterson, NJ 07501

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
23-3761.1	Field Blank	6-12-23	05:34	LEAD	200.8	<0.30	6-28-23	08:23	15
23-3761.2	3rd Floor Fountain	6-12-23	05:40	LEAD	200.8	<0.30	6-28-23	08:37	15
23-3761.3	2nd Floor Fountain	6-12-23	05:46	LEAD	200.8	<0.30	6-28-23	08:42	15
23-3761.4	Cafeteria Kitchen Sink	6-12-23	05:47	LEAD	200.8	<0.30	6-28-23	08:46	15
23-3761.5	Nurses Sink	6-12-23	05:50	LEAD	200.8	1.52	6-28-23	08:51	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L = micrograms of contaminant per liter of water, equivalent to ppb (parts per billion)
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-29-23

College Achieve Peterson Charter School
21 Market St.

6/12/23 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Laboratory Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	23-3761.1	JRH Labs	15083	6/12/2023	05:34	200.8	6/28/2023	08:23	<0.30	0.30	1	N	
3rd Floor Fountain	N	23-3761.2	JRH Labs	15083	6/12/2023	05:40	200.8	6/28/2023	08:37	<0.30	0.30	1	N	
2nd Floor Fountain	N	23-3761.3	JRH Labs	15083	6/12/2023	05:46	200.8	6/28/2023	08:42	<0.30	0.30	1	N	
Cafeteria/Kitchen Sink	N	23-3761.4	JRH Labs	15083	6/12/2023	05:47	200.8	6/28/2023	08:46	<0.30	0.30	1	N	
Nurses Sink	N	23-3761.5	JRH Labs	15083	6/12/2023	05:50	200.8	6/28/2023	08:51	1.52	0.30	1	N	

College Achieve Paterson Charter School

137 Ellison St.
Paterson, NJ 07505

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
137 Ellison St.
Paterson, NJ 07505

Sample Date: 8-24-23

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
23-5976.1	Field Blank	06:16	LEAD	200.8	<0.30	9/1/2023	13:09	15
23-5976.2	Kitchen-1st Floor	06:30	LEAD	200.8	0.81	9/1/2023	13:23	15
23-5976.3	Bathroom-3rd Floor	06:40	LEAD	200.8	2.78	9/1/2023	13:27	15
23-5976.4	Science Lab-2nd Floor	06:35	LEAD	200.8	0.37	9/1/2023	13:32	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 9-6-23

College Achieve Paterson Charter School
8/24/23 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	23-5976.1	JRH Labs	15083	8/24/2023	06:16	200.8	9/1/2023	13:09	<0.30	0.30	1	N	
Kitchen-1st Floor	N	23-5976.2	JRH Labs	15083	8/24/2023	06:30	200.8	9/1/2023	13:23	0.81	0.30	1	N	
Bathroom-3rd Floor	N	23-5976.3	JRH Labs	15083	8/24/2023	06:40	200.8	9/1/2023	13:27	2.78	0.30	1	N	
Science Lab-2nd Floor	N	23-5976.4	JRH Labs	15083	8/24/2023	06:35	200.8	9/1/2023	13:32	0.37	0.30	1	N	

College Achieve Paterson Charter School

5 Colt St.

Paterson, NJ 07505

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
5 Colt St.
Paterson, NJ 07505

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
23-3760.1	Field Blank	6-14-23	06:09	LEAD	200.8	<0.30	6-28-23	07:51	15
23-3760.2	Nurse Office	6-14-23	06:10	LEAD	200.8	<0.30	6-28-23	08:05	15
23-3760.3	Cafeteria Kitchen Sink	6-14-23	06:15	LEAD	200.8	0.31	6-28-23	08:10	15
23-3760.4	2 nd Floor Water Fountain	6-14-23	06:12	LEAD	200.8	0.60	6-28-23	08:14	15
23-3760.5	3 rd Floor Art Lab	6-14-23	06:17	LEAD	200.8	<0.30	6-28-23	08:19	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion)
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-29-23

College Achieve Paterson Charter School

5 Colt St.

6/14/23 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/l	Reporting Limit (ug/l)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	23-3760.1	JRH Labs	15083	6/14/2023	06:09	200.8	6/28/2023	07:51	<0.30	0.30	1	N	
Nurse Office	N	23-3760.2	JRH Labs	15083	6/14/2023	06:10	200.8	6/28/2023	08:05	<0.30	0.30	1	N	
Cafeteria/Kitchen Sink	N	23-3760.3	JRH Labs	15083	6/14/2023	06:15	200.8	6/28/2023	08:10	0.31	0.30	1	N	
2nd Floor Fountain	N	23-3760.4	JRH Labs	15083	6/14/2023	06:12	200.8	6/28/2023	08:14	0.60	0.30	1	N	
3rd Floor Art Lab	N	23-3760.5	JRH Labs	15083	6/14/2023	06:17	200.8	6/28/2023	08:19	<0.30	0.30	1	N	