

# **College Achieve Paterson Charter School**

**21 Market St.  
Paterson, NJ 07501**

## **Analytical Results for Lead**

**JR Henderson Labs, Inc.  
123 Seaman Ave.  
Beachwood, NJ 08722  
732-341-1211  
Lab #15083**

---

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Paterson Charter School  
21 Market St.  
Paterson, NJ 07501

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-5693.1	Field Blank	8-13-24	08:24	LEAD	200.8	<0.30	8-26-24	08:07	15
24-5693.2	3rd Floor Fountain	8-13-24	08:27	LEAD	200.8	<0.30	8-26-24	08:20	15
24-5693.3	Cafeteria	8-13-24	08:30	LEAD	200.8	1.46	8-26-24	08:29	15
24-5693.4	Nurses Sink	8-13-24	08:33	LEAD	200.8	0.30	8-26-24	08:34	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
< = less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 8-30-24

College Achieve Paterson Charter School  
21 Market St.

8/13/24 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lap Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-5693.1	JRH Labs	15083	8/13/2024	08:24	200.8	8/26/2024	08:07	<0.30	0.30	1	N	
3rd Floor Fountain	N	24-5693.2	JRH Labs	15083	8/13/2024	08:27	200.8	8/26/2024	08:20	<0.30	0.30	1	N	
Cafeteria	N	24-5693.3	JRH Labs	15083	8/13/2024	08:30	200.8	8/26/2024	08:29	1.46	0.30	1	N	
Nurses Sink	N	24-5693.4	JRH Labs	15083	8/13/2024	08:33	200.8	8/26/2024	08:34	0.30	0.30	1	N	

# College Achieve Paterson Charter School

47 State St.

Paterson, NJ 07505

## Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

---

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Paterson Charter School  
47 State St.  
Paterson, NJ 07505

Sample Date: 8-9-24

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-5166.1	Field Blank	14:15	LEAD	200.9	<2.00	8/15/2024	10:52	15
24-5166.2	Kitchen	14:28	LEAD	200.9	<2.00	8/15/2024	10:58	15
24-5166.3	1 <sup>st</sup> Floor Bathroom	14:34	LEAD	200.9	<2.00	8/15/2024	11:04	15
24-5166.4	Nurse Office	14:40	LEAD	200.9	<2.00	8/15/2024	11:10	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
<= less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 8-20-24

College Achieve Paterson Charter School

47 State St.

8/9/24 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-5166.1	JRH Labs	15083	8/9/2024	14:15	200.9	8/15/2024	10:52	<2.00	2.00	1	N	
Kitchen	N	24-5166.2	JRH Labs	15083	8/9/2024	14:28	200.9	8/15/2024	10:58	<2.00	2.00	1	N	
1st Floor Bathroom	N	24-5166.3	JRH Labs	15083	8/9/2024	14:34	200.9	8/15/2024	11:04	<2.00	2.00	1	N	
Nurse Office	N	24-5166.4	JRH Labs	15083	8/9/2024	14:40	200.9	8/15/2024	11:10	<2.00	2.00	1	N	

# College Achieve Paterson Charter School

137 Ellison St.  
Paterson, NJ 07505

## Analytical Results for Lead

JR Henderson Labs, Inc.  
123 Seaman Ave.  
Beachwood, NJ 08722  
732-341-1211  
Lab #15083

---

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Paterson Charter School  
137 Ellison St.  
Paterson, NJ 07505

Sample Date: 8-9-24

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-5165.1	Field Blank	16:00	LEAD	200.9	<2.00	8/15/2024	11:34	15
24-5165.2	Kitchen	16:04	LEAD	200.9	<2.00	8/15/2024	11:39	15
24-5165.3	Science Lab	16:10	LEAD	200.9	<2.00	8/15/2024	11:45	15
24-5165.4	1 <sup>st</sup> Floor Bathroom	16:12	LEAD	200.9	<2.00	8/15/2024	11:51	15

All samples were run unfiltered (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
<= less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 8-20-24



College Achieve Paterson Charter School  
 137 Ellison St.

8/9/24 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-5165.1	JRH Labs	15083	8/9/2024	16:00	200.9	8/15/2024	11:34	<2.00	2.00	1	N	
Kitchen	N	24-5165.2	JRH Labs	15083	8/9/2024	16:04	200.9	8/15/2024	11:39	<2.00	2.00	1	N	
Science Lab	N	24-5165.3	JRH Labs	15083	8/9/2024	16:10	200.9	8/15/2024	11:45	<2.00	2.00	1	N	
1st Floor Bathroom	N	24-5165.4	JRH Labs	15083	8/9/2024	16:12	200.9	8/15/2024	11:51	<2.00	2.00	1	N	

# College Achieve Paterson Charter School

59 Spruce St.  
Paterson, NJ 07505

## Analytical Results for Lead

JR Henderson Labs, Inc.  
123 Seaman Ave.  
Beachwood, NJ 08722  
732-341-1211  
Lab #15083

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Paterson Charter School  
59 Spruce St.  
Paterson, NJ 07505

Sample Date: 8-9-24

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-5167.1	Field Blank	14:40	LEAD	200.9	<2.00	8/15/2024	10:17	15
24-5167.2	Kitchen	14:59	LEAD	200.9	<2.00	8/15/2024	10:35	15
24-5167.3	1 <sup>st</sup> Floor Bathroom	14:46	LEAD	200.9	<2.00	8/15/2024	10:41	15
24-5167.4	Teachers Lounge	15:01	LEAD	200.9	<2.00	8/15/2024	10:46	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
< = less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 8-20-24

College Achieve Paterson Charter School  
59 Spruce St.

8/9/24 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-5167.1	JRH Labs	15083	8/9/2024	14:40	200.9	8/15/2024	10:17	<2.00	2.00	1	N	
Kitchen	N	24-5167.2	JRH Labs	15083	8/9/2024	14:59	200.9	8/15/2024	10:35	<2.00	2.00	1	N	
1st Floor Bathroom	N	24-5167.3	JRH Labs	15083	8/9/2024	14:46	200.9	8/15/2024	10:41	<2.00	2.00	1	N	
Teachers Lounge	N	24-5167.4	JRH Labs	15083	8/9/2024	15:01	200.9	8/15/2024	10:46	<2.00	2.00	1	N	

# College Achieve Paterson Charter School

5 Colt St.

Paterson, NJ 07505

## Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

---

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Paterson Charter School  
5 Colt St.  
Paterson, NJ 07505

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-5694.1	Field Blank	8-13-24	07:00	LEAD	200.8	<0.30	8-26-24	08:39	15
24-5694.2	Nurse Office	8-13-24	07:00	LEAD	200.8	0.38	8-26-24	08:52	15
24-5694.3	Cafeteria Kitchen Sink	8-13-24	07:05	LEAD	200.8	<0.30	8-26-24	08:57	15
24-5694.4	2 <sup>nd</sup> Floor Water Fountain	8-13-24	07:08	LEAD	200.8	0.32	8-26-24	09:01	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
<= less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 8-30-24

College Achieve Paterson Charter School

5 Colt St.

8/13/24 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-5694.1	JRH Labs	15083	8/13/2024	07:00	200.8	8/26/2024	08:59	<0.30	0.30	1	N	
Nurse Office	N	24-5694.2	JRH Labs	15083	8/13/2024	07:00	200.8	8/26/2024	08:52	0.38	0.30	1	N	
Cafeteria/Kitchen Sink	N	24-5694.3	JRH Labs	15083	8/13/2024	07:05	200.8	8/26/2024	08:57	<0.30	0.30	1	N	
2nd Floor Water Fountain	N	24-5694.4	JRH Labs	15083	8/13/2024	07:08	200.8	8/26/2024	09:01	0.32	0.30	1	N	