

College Achieve Paterson Charter School

21 Market St.
Paterson, NJ 07501

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
21 Market St.
Paterson, NJ 07501

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-5823.1	Field Blank	9/3/2025	06:36	LEAD	200.8	<0.30	9/10/2025	10:45	15
25-5823.2	3rd Floor Fountain	9/3/2025	06:41	LEAD	200.8	<0.30	9/10/2025	10:54	15
25-5823.3	Cafeteria	9/3/2025	06:44	LEAD	200.8	0.52	9/10/2025	10:57	15
25-5823.4	Nurses Sink	9/3/2025	06:46	LEAD	200.8	0.62	9/10/2025	11:00	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 9-11-25

College Achieve Paterson Charter School
21 Market St.

Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-5823.1	JRH Labs	15083	9/3/2025	06:36	200.8	9/10/2025	10:45	<0.30	0.30	1	N	
3rd Floor Fountain	N	25-5823.2	JRH Labs	15083	9/3/2025	06:41	200.8	9/10/2025	10:54	<0.30	0.30	1	N	
Cafeteria	N	25-5823.3	JRH Labs	15083	9/3/2025	06:44	200.8	9/10/2025	10:57	0.52	0.30	1	N	
Nurses Sink	N	25-5823.4	JRH Labs	15083	9/3/2025	06:46	200.8	9/10/2025	11:00	0.62	0.30	1	N	

College Achieve Paterson Charter School

47 State St.
Paterson, NJ 07505

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
47 State St.
Paterson, NJ 07505

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-4365-01	Field Blank	7-7-25	07:00	LEAD	200.9	<2.0	7-21-25	09:33	15
25-4365-02	Kitchen	7-7-25	07:00	LEAD	200.9	<2.0	7-21-25	09:51	15
25-4365-03	Staff Bathroom	7-7-25	07:00	LEAD	200.9	<2.0	7-21-25	09:57	15
25-4365-04	Boys Bathroom	7-7-25	07:00	LEAD	200.9	<2.0	7-21-25	10:03	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 7-21-25

College Achieve Paterson Charter School

47 State St.

Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-4365-01	JRH Labs	15083	7/7/2025	07:00	200.9	7/21/2025	09:33	<2.00	2.00	1	N	
Kitchen	N	25-4365-02	JRH Labs	15083	7/7/2025	07:00	200.9	7/21/2025	09:51	<2.00	2.00	1	N	
Staff Bathroom	N	25-4365-03	JRH Labs	15083	7/7/2025	07:00	200.9	7/21/2025	09:57	<2.00	2.00	1	N	
Boys Bathroom	N	25-4365-04	JRH Labs	15083	7/7/2025	07:00	200.9	7/21/2025	10:03	<2.00	2.00	1	N	

College Achieve Paterson Charter School

137 Ellison St.
Paterson, NJ 07505

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
137 Ellison St.
Paterson, NJ 07505

Sample Date: 7-22-24

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-4986.1	Field Blank	07:00	LEAD	200.9	<2.00	8/6/2025	09:23	15
25-4986.2	Kitchen	07:00	LEAD	200.9	<2.00	8/6/2025	09:41	15
25-4986.3	Girls Bathroom	07:00	LEAD	200.9	<2.00	8/6/2025	09:47	15
25-4986.4	Staff Bathroom	07:00	LEAD	200.9	<2.00	8/6/2025	09:53	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 8-7-25

College Achieve Paterson Charter School
137 Ellison St.
Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-4986.1	JRH Labs	15083	7/22/2025	07:00	200.9	8/6/2025	09:23	<2.00	2.00	1	N	
Kitchen	N	25-4986.2	JRH Labs	15083	7/22/2025	07:00	200.9	8/6/2025	09:41	<2.00	2.00	1	N	
Girls Bathroom	N	25-4986.3	JRH Labs	15083	7/22/2025	07:00	200.9	8/6/2025	09:47	<2.00	2.00	1	N	
Staff Bathroom	N	25-4986.4	JRH Labs	15083	7/22/2025	07:00	200.9	8/6/2025	09:53	<2.00	2.00	1	N	

College Achieve Paterson Charter School

6 Wall St.

Passaic, NJ 07055

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
6 Wall St.
Passaic, NJ 07055

Sample Date: 7-23-25

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-4985.1	Field Blank	08:00	LEAD	200.9	<2.00	8/6/2025	10:17	15
25-4985.2	Kitchen	08:00	LEAD	200.9	<2.00	8/6/2025	10:52	15
25-4985.3	Boys Bathroom	08:00	LEAD	200.9	<2.00	8/6/2025	10:58	15
25-4985.4	Staff Bathroom	08:00	LEAD	200.9	<2.00	8/6/2025	11:04	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 8-7-25

College Achieve Paterson Charter School
6 Wall St.

Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-4985.1	JRH Labs	15083	7/23/2025	08:00	200.9	8/6/2025	10:17	<2.00	2.00	1	N	
Kitchen	N	25-4985.2	JRH Labs	15083	7/23/2025	08:00	200.9	8/6/2025	10:52	<2.00	2.00	1	N	
Boys Bathroom	N	25-4985.3	JRH Labs	15083	7/23/2025	08:00	200.9	8/6/2025	10:58	<2.00	2.00	1	N	
Staff Bathroom	N	25-4985.4	JRH Labs	15083	7/23/2025	08:00	200.9	8/6/2025	11:04	<2.00	2.00	1	N	

College Achieve Paterson Charter School

5 Colt St.

Paterson, NJ 07505

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Paterson Charter School
5 Colt St.
Paterson, NJ 07505

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-6034.1	Field Blank	9-2-25	06:45	LEAD	200.8	<0.30	9-17-25	12:21	15
25-6034.2	2nd Floor Café	9-2-25	06:55	LEAD	200.8	<0.30	9-17-25	12:30	15
25-6034.3	1st Floor Bathroom	9-2-25	06:50	LEAD	200.8	<0.30	9-17-25	12:33	15
25-6034.4	2nd Floor Water Fountain	9-2-25	06:53	LEAD	200.8	<0.30	9-17-25	12:36	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 9-18-25

College Achieve Paterson Charter School
5 Colt St.

Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-6034.1	JRH Labs	15083	9/2/2025	06:45	200.8	9/17/2025	12:21	<0.30	0.30	1	N	
2nd Floor Café	N	25-6034.2	JRH Labs	15083	9/2/2025	06:55	200.8	9/17/2025	12:30	<0.30	0.30	1	N	
1st Floor Bathroom	N	25-6034.3	JRH Labs	15083	9/2/2025	06:50	200.8	9/17/2025	12:33	<0.30	0.30	1	N	
2nd Floor Water Fountain	N	25-6034.4	JRH Labs	15083	9/2/2025	06:53	200.8	9/17/2025	12:36	<0.30	0.30	1	N	